



215 Colonnade Road South Phone: (613)225-9531
Ottawa, Ontario Fax: (613)225-6965
K2E 7K3 Toll Free: 1-800-465-5777
www.armstrongmonitoring.com

CERTIFICATE OF CALIBRATION

The Armstrong Monitoring Corporation certifies that this gas detection equipment has been calibrated to accepted industry standards.

Site Information:

TAMARACK WELLINGTON
10 ROSEMOUNT AVE
OTTAWA

System Information

Location: P1 Electrical Room
Manufacturer: Honeywell
Part Number: 301C
Serial Number: N/A

Peripheral Device Status:

All peripheral devices have been verified to be working properly as noted on work order

Sensor Information

Sensor #:	Part #:	Serial #:	GasType:	Alarm Settings:			Status:
2	E3SM	NM131600055	Nitrogen Dioxide	0.7ppm	2.0ppm	9.0ppm	PASS
1	E3SM	NM131600086	Carbon Monoxide	25ppm	75ppm	75ppm	PASS
4	E3SM	NM131600078	Nitrogen Dioxide	0.7ppm	2.0ppm	9.0ppm	PASS
3	E3SM	NM131600057	Carbon Monoxide	25ppm	75ppm	75ppm	PASS
6	E3SM	NM131600087	Nitrogen Dioxide	0.7ppm	2.0ppm	9.0ppm	PASS
5	E3SM	NM131600084	Carbon Monoxide	25ppm	75ppm	75ppm	PASS
8	E3SM	NM131600056	Nitrogen Dioxide	0.7ppm	2.0ppm	9.0ppm	PASS
7	E3SM	NM131600085	Carbon Monoxide	25ppm	75ppm	75ppm	PASS

Calibration Date: 3/28/2019

Next Recommended Calibration Date: 9/28/2019

Calibration Technician

Craig Barrows

